



Blended Fuel Compatibility Form

Facility - 2046827

Facility Name	Thorntons #329
Address	1321 N Joliet Rd Romeoville, IL 60446
County	Will
Contact Name	Mike Carter
Phone Number	(630) 743-3605

Tank - 3

Tank Material	Fiberglass Brine Filled Double Wall
Tank Capacity	6,000
Tank Product	E85
Tank Install Date	6/5/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval	2+Tank+Sumps+Xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	3+Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	Bravo	Manufacturer Approval	4+UDC+Bravo.pdf	
Single Wall STP/Tanktop Sump	XERXES SW Fiberglass Tank Sumps	Manufacturer Approval	2+Tank+Sumps+Xerxes.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410	Manufacturer Approval	5+Probe+Float.pdf	
Required Other Monitor only for sensors	Veeder Root TLS 450 Plus	Manufacturer Approval	Veeder Root Compatibility Letter.pdf	New from Permit Application.
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-303	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-003	Manufacturer Approval	7+E85+Compatibility+TLS+P roducts.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	6+Sensors+VR323+VR303.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling Defender 705	Manufacturer Approval	8+Spill+Bucket+Franklin.p df	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	9+Overfill+Prevention+Valve+OPW.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump	Franklin Fueling IST	Manufacturer Approval	10+Pump+Franklin.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets & Seals	Wayne Dispensers Helix	Manufacturer Approval	11+Dispenser+Meter+Wayne.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Joint Dopes & Adhesives	Gasolia E-Seal	Manufacturer Approval	12+Gasolia.pdf	

Correspondence Contact

<p>Submitter Name Amber Pena</p> <p>Job Title Director of Service</p> <p>Company Stenstrom Petroleum Services Group</p> <p>Phone Number (815) 398-6250</p> <p>Email amberp@rstenstrom.com</p> <p>Contractor License # IL1890</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
--	--