

CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-MH1821
Report Reference MH1821-20020809
Issue Date 2019-MARCH-01

Issued to: WAYNE FUELING SYSTEMS LLC
3814 JARRETT WAY
AUSTIN TX 78728

**This certificate confirms that
representative samples of**

FLAMMABLE LIQUID DISPENSING DEVICES, POWER
OPERATED

See addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

See addendum page

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190301-MH1821
Report Reference MH1821-20020809
Issue Date 2019-MARCH-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Remote Control Models:

Power-operated flammable liquid dispensing devices, Ovation Series, Model B, R, HL or HS followed by 1 or 2, followed by 1, 2, 3 or 4, followed by 1, 2, 3, 4 or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, 1, 3, 4, 5, 6, or 7, followed by C, D, or S followed by 0, 1, 2, 3, 4, 7, 8 or D6, may be followed by one or more of the following option suffixes, 2, 6, 7, 9, E, G, H, I, J, K, L, L1, M, N, P, S, T, or U, followed by one or more of the following option suffixes A, C, D, F, F1, G, H, L, M, N, O, R, R3 U, V, W, W1, X, Y, or Z.

Power-operated flammable liquid dispensing devices, Ovation Series, Model B, R, HL followed by 1 or 2, followed by 1, 2, 3 or 4, followed by 1, 2, 3, 4 or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, followed by C, D, or S followed by 1, 2, 3, 4, 7, 8, or D6, may be followed by one or more of the following option suffixes, 2, 6, G, I, J, K, L, L1, M, N, P, S, T, or U, followed by one or more of the following option suffixes A, F, F1, G, H, L, M, N, O, R, R3 U, V, W, W1, X, or Y.

Power-operated flammable liquid dispensing devices, Ovation Series, Model E, followed by B or R, followed by 1 or 2, followed by 1, 2, 3, or 4 followed by 1, 2, 3, 4, or 5, followed by 1 or 2, followed by 1 or 2, followed by 0, followed by D, followed by 0, 1, 2, 3, 4, 7, 8, or D6, may be followed by one or more of the following option suffixes, C, D, E, G, H, I, J, K, L, L1, M, M2 N, P, R, R3, S, T, U, W, W1, X, Y, 6 and 7.

Standard(s) for Safety:

UL 1238, Control Equipment for Use With Flammable Liquid Dispensing Devices

UL 87, Power-Operated Dispensing Devices For Petroleum Products

CAN/CSA B346-M1980, Power-Operated Dispensing Devices for Flammable Liquids

C22.2 No. 22-2018, Electrical Equipment for Flammable and Combustible Fuel Dispensers

UL 121201 Nonincendive Electrical Equipment for use in Class I and II, Division 2 And Class III, Divisions 1 and 2 Hazardous (Classified) Locations

CSA C22.2 No. 213-2017, Nonincendive Electrical Equipment for use in Class I and II, Division 2 And Class III, Divisions 1 and 2 Hazardous (Classified) Locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



EWTV2.GuidelInfo - FLAMMABLE LIQUID DISPENSING DEVICES, POWER OPERATED - COMPONENT

[Dispensing Devices - Component] (Power-operated Dispensing Devices - Component) Flammable Liquid Dispensing Devices, Power Operated - Component

See General Information for Power-operated Dispensing Devices - Component

The devices covered under this category are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. THE FINAL ACCEPTANCE OF THE COMPONENT IS DEPENDENT UPON ITS INSTALLATION AND USE IN COMPLETE EQUIPMENT SUBMITTED TO UL.

USE

This category covers power-operated dispensing-device components.

A power-operated dispensing device establishes hazardous (classified) locations in and around the product as a result of its design and construction and is not intended to be used in hazardous (classified) locations resulting from external factors, such as installation near aboveground tanks, LP gas or CNG dispensers. The dispensing device has Class I, Group D, Division 1 and 2 locations within it but may also contain areas that are unclassified because of the dispenser construction.

These products are intended for use with fuels formulated in accordance with 40CFR80, "Regulation of Fuels and Fuel Additives," and the following:

- a) Gasoline formulated in accordance with ANSI/ASTM D4814, "Standard Specification for Automotive Spark-Ignition Engine Fuel"
- b) Gasoline/ethanol blends at levels designated as "gasohol" (E10 maximum) formulated in accordance with ANSI/ASTM D4814, when blended with denatured fuel ethanol formulated in accordance with ANSI/ASTM D4806, "Standard Specification for Denatured Fuel Ethanol for Blending with Gasolines for Use as Automotive Spark-Ignition Engine Fuel"
- c) Gasoline/ethanol blends formulated in accordance with ANSI/ASTM D5798, "Standard Specification for Fuel Ethanol (Ed75 - Ed85) for Automotive Spark-Ignition Engines"
- d) Diesel fuel formulated in accordance with ANSI/ASTM D975, "Standard Specification for Diesel Fuel Oils"
- e) Heating fuels formulated in accordance with ANSI/ASTM D396, "Standard Specification for Fuel Oils," and ANSI/ASTM D3699, "Standard Specification for Kerosine"

CONDITIONS OF ACCEPTABILITY

Consideration is to be given to the Conditions of Acceptability specified in the individual Reports when these components are employed in the end-use equipment.

REQUIREMENTS

The basic standard used to investigate products in this category is one of the following:

UL 87, "Power-Operated Dispensing Devices for Petroleum Products" — For products intended for use with gasoline or gasoline/ethanol blends with nominal ethanol concentrations up to 10 percent (gasohol, E10), diesel fuel, diesel/biodiesel blends with nominal biodiesel concentrations up to 5 percent (B5), kerosene, or fuel oil.

ANSI/UL 87A, "Power-Operated Dispensing Devices for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0 - E85)" — For products intended for use with gasoline or gasoline/ethanol blends with nominal ethanol concentrations up to 85 percent (E85).

ANSI/UL 87B, "Power-Operated Dispensing Devices for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations up to 20 Percent (B20), Kerosene, and Fuel Oil" — For products intended for use with diesel fuel, biodiesel fuel, diesel/biodiesel blends with nominal biodiesel concentrations up to 20 percent (B20), kerosene or fuel oil.

UL 87C, "Outline of Investigation for Power-Operated Dispensing Devices for Diesel Exhaust Fluid" — For products intended for use with diesel exhaust fluid.

UL MARKING

Components Recognized under UL's Component Recognition Program are identified by markings consisting of the Recognized company's identification and catalog, model or other product designation provided on or with each assembly. In addition, components produced under the UL Component Recognition Program will also bear the Recognized Component Mark .

The Listing or Classification Mark of UL is not authorized for use on, or in connection with, Recognized Components. Only those components that actually bear the "Marking" should be considered as being covered under the Component Recognition Program.

* * * * *

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

Last Updated on 2014-10-31

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"