



### Blended Fuel Compatibility Form

Facility - 2006664

<b>Facility Name</b>	380 South Elgin, LLC
<b>Address</b>	380 N. La Fox Street South Elgin, IL 60177
<b>County</b>	Kane
<b>Contact Name</b>	Ibrima Sallah
<b>Phone Number</b>	(224) 239-2013

Tank - 9

<b>Tank Material</b>	Steel Single Wall
<b>Tank Capacity</b>	2,000
<b>Tank Product</b>	E85
<b>Tank Install Date</b>	12/30/1987

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Single Wall	UNKNOWN	Lab Certification	sti_fuels_compatibility_statement.pdf	
Lining Materials Internal	Existing	Manufacturer Approval	armor shield tl-300 lining.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW 10	Manufacturer Approval	opw_all_products.pdf	
Flexible Double Wall	Environ Geo Flex	Manufacturer Approval	flexpip4_EPA_OUST_Letter_Piping_Suppliers.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	ENVIRON	Manufacturer Approval	flexpip4_EPA_OUST_Letter_Piping_Suppliers.pdf	
Single Wall UDC Sump	ENVIRON	Manufacturer Approval	flexpip4_EPA_OUST_Letter_Piping_Suppliers.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VEEDER-ROOT 846397	Manufacturer Approval	veeder_root_probes.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root 848480-001	Manufacturer Approval	Veeder-Root PLLD.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Emco - A1004EVR-316S	Manufacturer Approval	Emco A1004 & 1005 containers.pdf	Replacing from Permit Application.

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender 708693924	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Fe Petro AG	Manufacturer Approval	E85 submersible info sheet.pdf	
Dispenser	Wayne Ovation 2 EB23	Manufacturer Approval	Wayne Ovation EB23.pdf	
Nozzle	OPW 11BP	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Goodyear	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill cap	OPW	Manufacturer Approval	opw-634-series-tight-fill - top-seal-caps-2018.pdf	

### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasoil E-Seal	Manufacturer Approval	gasoil dope.pdf	

### Correspondence Contact

**Submitter Name** Ben Olthoff  
**Job Title** Project Manager  
**Company** B & K Equipment Company  
**Phone Number** (708) 474-3344  
**Email** ben.olthoff@bkequip.com  
**Contractor License #** IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.