



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 1024482

Facility Name Sapp Bros. Travel Centers,
Inc.
Address 3130 May Road
Peru, IL 61354
County LaSalle
Contact Name Kevin Cassidy
Phone Number (815) 224-1065

Tank - 7

Tank Material Fiberglass Single Wall
Tank Capacity 12,000
Tank Product B-99
Tank Install Date 6/1/1988

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Owens Corning lined with Glass Armor GA 27P	Manufacturer Approval	COMPATIBILITY LETTER.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW / Polyethylene Pisco	Manufacturer Approval	Sapp below-ground-product s-fuel-compatibility-matrix-2018.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder-Root / 847390-107	Manufacturer Approval	Sapp Veeder-Root - Fuel Compatibility Letter.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Fe Petro / STP-MLD+BD	Manufacturer Approval	SAPPBRO-MLD-BD-B99 10-17- 22.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder-Root / 794380-430	Manufacturer Approval	Sapp 794380-430 VeederRoot Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW / 1-2200	Manufacturer Approval	Sapp below-ground-product s-fuel-compatibility-matrix-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder/Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Red Jacket / AGP200S1-3 RJ2	Manufacturer Approval	Sapp Red Jacket STP B99 & E85.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Anthony Mannino

Job Title Project Manager

Company Illinois Oil Marketing Equipment

Phone Number (309) 202-0792

Email amannino@iome.com

Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.