



Blended Fuel Compatibility Form

Facility - 2016473

Facility Name Arlington BP (GEI-158)
Address 2250 South Arlington Heights Rd.
 Arlington Heights, IL 60005
County Cook
Contact Name Andy Leszczynski
Phone Number (708) 927-3583

Tank - 9

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 10/12/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
OPW Shear Valves	10 Series	Manufacturer Approval		
Flex connector	OPW-FC-Series Stainless Steel	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes Fiberglass Sump	Manufacturer Approval		
UDC Containment Sump	B-1000 - Bravo Fiberglass Sump	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	794380-345 Solid State Discriminating Interstitial Sensor	Manufacturer Approval		
ATG Probe	846391 Probe Alt. Fluid 0.1 Mag Plus HGP, No water Sensor	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	848480-003 Pressurized Line Leak Detector	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	794380-323 Position Sensitive Pan/Sump Sensor	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	705545011 Single wall spill bucket Franklin Fuel Defender Series 5-Gallon	Manufacturer Approval		See page (12) for the Compatibility statement
UDC-Dispenser Sump	Bravo-B7	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	61SOM EVR opw Overfill Valve E-85	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
F.E. Petro AG Submersible Pump	F.E. PETRO-STPAGR200	Manufacturer Approval		
USC-Submersible Sumps	Xerxes- Fiberglass Sump	Manufacturer Approval		
Nozzles	OPW-11BP-E85 Series	Manufacturer Approval		
Hoses	Goodyear/Continental	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia E-Seal	E-Seal Pipe Dope	Manufacturer Approval		

Correspondence Contact

Submitter Name Raymond Kirchner
Job Title Construction Supervisor
Company Graham Enterprise, Inc.
Phone Number (708) 243-1199
Email rkirchner@grahamei.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.