

**Blended Fuel Compatibility Form****Facility - New**

Facility Name QuikTrip #4423
Address 4025 Algonquin Road
Rolling Meadows, IL 60008
County Cook
Contact Name Kyla Rudd
Phone Number (918) 655-7700

Tank - 3

Tank Material Tank - Fiberglass Brine Filled
Double Wall XERXES
Tank Capacity 15,000
Tank Product E15
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Tanks.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech	Manufacturer Approval	Franklin Fueling APT Flex ible Pipework Datasheet.p df	New from Permit Application.
Ball Valves	Jomar	Manufacturer Approval	Jomar+Ball+Valve.pdf	New from Permit Application.
Flex Connector Steel	Hose Master	Manufacturer Approval	Hosemaster+Flex+Connector s.pdf	New from Permit Application.
Shear Valves	OPW	Manufacturer Approval	OPW+Shear+Valve.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	PCI	Manufacturer Approval	PCI+Sumps.pdf	New from Permit Application.
Single Wall Transition Sump	PCI	Manufacturer Approval	PCI+Sumps.pdf	New from Permit Application.
Dispenser Containment Sumps	Bravo	Manufacturer Approval	Bravo Dispenser Sump.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-303	Manufacturer Approval	Veeder+Root+Sump+&+Inters titial+Sensors (1).pdf	New from Permit Application.
ATG Probe	Veeder Root 846397-409	Manufacturer Approval	Veeder+Root+Probe+&+Float (1).pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Manufacturer Approval	PLLD+VR859080-001.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 794380-208	Manufacturer Approval	Veeder+Root+Sump+&+Intertial+Sensors (1).pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3110	Manufacturer Approval	OPW+Compatibility+Matrix.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling 708592922	Manufacturer Approval	FFS-0392+Defender+Series+OPV+Datasheet.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro	Manufacturer Approval	FFS-0796+Submersible+Turbine+Pumps+Datasheet.pdf	
Dispenser	Gilbarco	Manufacturer Approval	Gilbarco+Dispenser+Compatibility.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Gilbarco	Manufacturer Approval	Gilbarco+Dispenser+Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola	Manufacturer Approval	Gasola.pdf	

Correspondence Contact

Submitter Name Nick Bugajsky
Job Title Project Manager
Company Stenstrom Petroleum Services Group
Phone Number (630) 606-0996
Email nickb@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.