



## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

### Blended Fuel Compatibility Form

#### Facility - 2025232

**Facility Name** 908 Streamwood, LLC  
**Address** 908 East Irving Park Road  
Streamwood, IL 60107  
**County** Cook  
**Contact Name** Jabel Sallah  
**Phone Number** (224) 239-2013

#### Tank - 6

**Tank Material** Composite Double Wall  
**Tank Capacity** 8,000  
**Tank Install Date** 8/8/2003  
**Current Product on File** Gasoline - Premium  
**Newly Reported Product** E85

#### Tank Equipment

| Compatibility Item    | Model/Manufacturer | Compatibility Method  | Documentation                               | Comment |
|-----------------------|--------------------|-----------------------|---------------------------------------------|---------|
| Composite Double Wall | Glasteel II        | Manufacturer Approval | Glasteel II BioFuels Compatibility 2018.pdf |         |

#### Piping Equipment

| Compatibility Item   | Model/Manufacturer | Compatibility Method  | Documentation                                 | Comment |
|----------------------|--------------------|-----------------------|-----------------------------------------------|---------|
| Flexible Double Wall | Environ Geo Flex   | Manufacturer Approval | flexpip4 EPA OUST Letter Piping Suppliers.pdf |         |
| Shear Valve          | OPW 10             | Manufacturer Approval | OPW compatibility.pdf                         |         |

#### Containment Sump Equipment

| Compatibility Item           | Model/Manufacturer | Compatibility Method  | Documentation                                 | Comment |
|------------------------------|--------------------|-----------------------|-----------------------------------------------|---------|
| Single Wall STP/Tanktop Sump | ENVIRON            | Manufacturer Approval | flexpip4 EPA OUST Letter Piping Suppliers.pdf |         |
| Single Wall UDC Sump         | ENVIRON            | Manufacturer Approval | flexpip4 EPA OUST Letter Piping Suppliers.pdf |         |

#### Release Detection Tank Equipment

| Compatibility Item                                 | Model/Manufacturer     | Compatibility Method  | Documentation               | Comment |
|----------------------------------------------------|------------------------|-----------------------|-----------------------------|---------|
| Non-Discriminating Interstitial Monitoring Sensors | Veeder-Root 794380-430 | Manufacturer Approval | veeder root sensors all.pdf |         |
| ATG Probe                                          | Veeder-Root 846397     | Manufacturer Approval | veeder root probes.pdf      |         |

#### Release Detection Piping Equipment

| Compatibility Item                          | Model/Manufacturer     | Compatibility Method  | Documentation               | Comment |
|---------------------------------------------|------------------------|-----------------------|-----------------------------|---------|
| Electronic Pressurized Line Leak Detection  | Veeder-Root 848480-001 | Manufacturer Approval | Veeder-Root PLLD.pdf        |         |
| Sump Sensor in Single Wall STP/Tanktop Sump | Veeder-Root 794380-323 | Manufacturer Approval | veeder root sensors all.pdf |         |

#### Spill Prevention Equipment

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation            | Comment |
|--------------------------|--------------------|-----------------------|--------------------------|---------|
| Single Wall Spill Bucket | OPW 1              | Manufacturer Approval | Opw spill containers.pdf |         |

#### Overfill Prevention Equipment

| Compatibility Item       | Model/Manufacturer   | Compatibility Method  | Documentation                              | Comment |
|--------------------------|----------------------|-----------------------|--------------------------------------------|---------|
| Overfill Drop Tube Valve | FRANKLIN FUELING 708 | Manufacturer Approval | FFS-0392 Defender Series OPV Datasheet.pdf |         |

### Pump Equipment

| Compatibility Item       | Model/Manufacturer   | Compatibility Method  | Documentation                             | Comment |
|--------------------------|----------------------|-----------------------|-------------------------------------------|---------|
| Submersible Turbine Pump | Fe Petro AG          | Manufacturer Approval | franklin stp.pdf                          |         |
| Dispenser                | Wayne Ovation 2 EB23 | Manufacturer Approval | Wayne Ovation EB23.pdf                    |         |
| Nozzle                   | OPW 11BP             | Manufacturer Approval | opw-11bp-series-ethanol-nozzles_2018.pdf  |         |
| Hose                     | Goodyear             | Manufacturer Approval | Continental_Goodyear_flex steel hoses.pdf |         |

### Gaskets & Seals Equipment

| Compatibility Item  | Model/Manufacturer | Compatibility Method  | Documentation        | Comment |
|---------------------|--------------------|-----------------------|----------------------|---------|
| Fill and vapor caps | OPW                | Manufacturer Approval | opw all products.pdf |         |

### Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method  | Documentation   | Comment |
|--------------------|--------------------|-----------------------|-----------------|---------|
| Thread sealant     | Gasoil E-Seal      | Manufacturer Approval | gasoil dope.pdf |         |

### Correspondence Contact

**Submitter Name** Jim Veverka  
**Job Title** PROJECT MANAGER  
**Company** B&K Equipment Company  
**Phone Number** (708) 474-3344  
**Email** jim.veverka@bkequip.com  
**Contractor License #** IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.