

**Blended Fuel Compatibility Form**

Facility - 5046190

Facility Name Love's Travel Stop #687
Address 228 Moeller Rd.
South Jacksonville, IL 62650
County Morgan
Contact Name Kyle Collins
Phone Number (405) 834-0311

Tank - 6

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 8/4/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NOV ? AO Smith	Red Thread IIA	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval		
Single Wall Transition Sump	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling	Manufacturer Approval		
ATG Probe	Franklin Fuelling	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Franklin Fueling	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall Transition Sump	Franklin Fueling	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root	Manufacturer Approval		
Overfill Drop Tube Valve	Franklin Fueling - 708591921	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Franklin Fueling	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Anthony Mannino
Job Title Project Manager
Company Illinois Oil Marketing Equipment
Phone Number (309) 202-0792
Email amannino@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.