

**Blended Fuel Compatibility Form**

Facility - 2045451

Facility Name Lenny's Food N Fuel, LLC
Address 2560 Cedar Ave.
NEC Cedar & US Route 6
New Lenox, IL 60451
County Will
Contact Name Caryn Walker
Phone Number (815) 463-8200

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 10/2/2013

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	Xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	opw	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	
Flex connectors	Franklin	Lab Certification	Fire flex flexes.pdf	
Other Riser	NOV Fiberglass Red Thread	Lab Certification	NOV RedThreadAlcohol Comp atibility.pdf	New from Permit Application.
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC	Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Xerxes	Lab Certification	Xerxes Containment Sump U pgrades (1).pdf	
Single Wall UDC Sump	Bravo	Manufacturer Approval	e85 bravo.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Sensor	Veeder Root	Manufacturer Approval	Veeder Root Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root plld	Manufacturer Approval	e85 plld.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794390-323	Lab Certification	Veeder Root Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Model 705-550 Series	Lab Certification	Defender spill bucket Fra nklin.pdf	Replacing from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 71SOM	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Gilbarco	Lab Certification	Gilbarco.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Keenan Ary

Job Title Pipefitter

Company Anderson Pump Service, Inc.

Phone Number (630) 484-7474

Email KeenanA@andersonpump.com

Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.