

**Blended Fuel Compatibility Form**

Facility - 2034701

Facility Name Petroleum Investment Properties, LLC
Address 11900 Marshfield
Calumet Park, IL 60409
County Cook
Contact Name Nasr Ali
Phone Number (773) 971-9900

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 5,000
Tank Product E-85
Tank Install Date 5/3/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump, Bravo dispenser sump	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, part #794380-345	Manufacturer Approval		
ATG Probe	Veeder Root, part #846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root, part #794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin, EBW defender overspill, part #705556111BLK	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW, part #71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible	FE Petro	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Warren Cherner

Job Title President

Company Metro Tank and Pump Company

Phone Number (847) 465-4000

Email warren@metrotank.com

Contractor License # IL102

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.