

**Blended Fuel Compatibility Form**

Facility - 2021035

Facility Name Citgo Gas Station
Address 5150 West Chicago Avenue
Chicago, IL 60651
County Cook
Contact Name Fadi Khalil
Phone Number (773) 261-6310

Tank - 7

Tank Material Tank - Composite Double
Wall Lannon
Tank Capacity 6,000
Tank Product E-85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Lannon	Manufacturer Approval	Lannon Tank Compatibility .pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval	franklin apt pipe.pdf	From Permit Application
Submersible pump	FE Petro 75AG	Manufacturer Approval	E85 submersible info sheet.pdf	From Permit Application
Ball Valves	Morrison 691BSS	Manufacturer Approval	Morrison ball valve.pdf	From Permit Application
Shear Valves	OPW	Manufacturer Approval	OPW compatibility.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo B421	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	From Permit Application
Single-wall UDC	Bravo B9000	Manufacturer Approval	Bravo UDC.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root 794380-430	Manufacturer Approval	VR sensor.pdf	From Permit Application
ATG Probe	Veeder-Root 846397	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro Stp MLD AG	Manufacturer Approval	MLD AG.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder-Root 794380-323	Manufacturer Approval	veeder root sensors all.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112D	Manufacturer Approval	Opw spill containers.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	71SOM_Overfill_Prevention_Valve.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
3+1 dispenser	Wayne Ovation2 EB23	Lab Certification	Wayne Ovation EB23.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill and vapor caps	OPW	Manufacturer Approval	OPW compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasola E-Seal	Manufacturer Approval	gasola dope.pdf	

Correspondence Contact

Submitter Name Jim Veverka
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 474-3344
Email jim.veverka@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.