

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 2046413

Facility Name Speedway #4440
Address 38980 N. Green Bay Rd.
 Beach Park, IL 60087
County Lake
Contact Name Melonie Hart
Phone Number (708) 444-7086

Tank - 1

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 7/27/2017

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Double Wall Containment Solutions	Containment Solutions	Manufacturer Approval	biofuel-compatibi...	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Flexible Double Wall OPW Flexworks	OPW Flexworks	Manufacturer Approval	opw-fuel-compatib...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	OPW Fiberglass	Manufacturer Approval	opw-fuel-compatib...	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veedor-Root/794380-345	Manufacturer Approval	577013-750-13_Sol...	
ATG Probe	Veeder-root/332812-001	Manufacturer Approval	577014-449-08_Sta...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressurized Line Leak Detection	Veedor-root/859080-001	Manufacturer Approval	576047-319_Electr...	
Non-Discriminating Sump Sensor with positive shutdown in Piping - Single Wall STP/Tanktop Sump	Veedor-root/794380-323	Manufacturer Approval	577013-750-10_Pos...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Single Wall Spill Bucket	OPW1C-2100 Series	Manufacturer Approval	opw-fuel-compatib...	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill	Veedor-Root/790091-001	Manufacturer	576047-311_Overfi	From Permit

Alarm	Model/Manufacturer	Compatibility Method	Documentation	Application Comment
Overfill Prev Device - Overfill Alarm	Veedor-Root/790095-001	Manufacturer Approval	576047-241_Overfi...	
Overfill Prev Device - Overfill Drop Tube Valve	OPW-71SOM Overfill Valve	Manufacturer Approval	opw-fuel-compatib...	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayn Fuel Dispenser	WAYNE HELIXTM 4000 FUEL DISPENSER	Manufacturer Approval	f2e78a_835d0167ea...	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravi Penmatsa
Job Title Business Manager
Company America Petropump Services LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.