



Blended Fuel Compatibility Form

Facility - 4007142		Tank - 7	
Facility Name	Circle K #1404	Tank Material	Fiberglass Brine Filled Double Wall
Address	1212 North Bowman Danville, IL 61832	Tank Capacity	4,000
County	Vermilion	Tank Product	E-85
Contact Name	Trista Y.	Tank Install Date	11/14/2007
Phone Number	(217) 431-3750		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron (Aka NOV) / LCX	Manufacturer Approval		6/6/22 uploaded documentation for LCX piping. See description section for compa...

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP Sump	Containment Solutions	Manufacturer Approval		
Dispenser Sump	OPW Poly Sump	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval		
ATG Probe	Veeder Root 864391-404	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Red Jacket 116-056-5	Manufacturer Approval		
STP Sump Sensor	Veeder Root / 794380-351	Manufacturer Approval		
Under dispenser containment leak detection	Veeder Root / 794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Gilbarco Advantage	Manufacturer Approval		The Advantage dispenser has a Liqua-Tech LPM-101E meter for Ethanol.

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Skip Aulgur

Job Title Estimator

Company Neumayer Equipment Co

Phone Number (314) 497-9884

Email skip_aulgur@neumayerequipment.com

Contractor License # IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.