



### Blended Fuel Compatibility Form

Facility - 2042386

Tank - 4

<b>Facility Name</b>	Pilot Travel Center #473
<b>Address</b>	23841 West Eames Street Channahon, IL 60410
<b>County</b>	Will
<b>Contact Name</b>	Markisha Gamble
<b>Phone Number</b>	(815) 467-4455

<b>Tank Material</b>	Steel Double Wall
<b>Tank Capacity</b>	20,000
<b>Tank Product</b>	B-99
<b>Tank Install Date</b>	5/15/2008

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Double Wall	Highland Tank Titan Jacketed	Manufacturer Approval	highland-tank.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Single Wall Piping	Flex-ing	Lab Certification	ffs-0271-ul-flexible-connectors-datasheet.pdf	From Permit Application
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy 3000 LCX Data Sheet.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Bio-heater Tank Top Sump	OPW Single Walled Fiberglass Sump	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Single Wall Bio Heater Tank Top Sump	OPW Single Walled Fiberglass Sump	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Single Wall Suction/Tank-top Sump	OPW Single Walled Fiberglass Sump	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root / 846391 Mag Plus Probe	Manufacturer Approval	VR Mag Plus Probe Biodiesel Compatibility Letter 9-2-22.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-430	Manufacturer Approval	794980-430 High Alcohol Int Sensor Steel Tanks.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor in Single Wall Transition Sump South	Veeder Root / 794380-321	Manufacturer Approval	Non Discriminating Leak Sensor 794380-321.pdf	
Non-Discriminating Sump Sensor in Single Wall Transition Sump North	Veeder Root / 794380-321	Manufacturer Approval	Non Discriminating Leak Sensor 794380-321.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / 794380-321	Manufacturer Approval	Non Discriminating Leak Sensor 794380-321.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO-410CB	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp	Manufacturer Approval	Gorman Rupp Bio Pump.pdf	

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

<b>Submitter Name</b>	Madeline Kingery	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	service manager	
<b>Company</b>	Northern Indiana Mechanical Inc	
<b>Phone Number</b>	(219) 963-1640	
<b>Email</b>	nimco653@hotmail.com	
<b>Contractor License #</b>	IL292	