



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 3047129

Facility Name Beck Oil #30
Address 1311 Washington Rd.
Washington, IL 61571
County Tazewell
Contact Name Bill Smith
Phone Number (815) 875-6451

Tank - 6

Tank Material Composite Double Wall
Tank Capacity 6,000
Tank Product E-15
Tank Install Date 10/22/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
EBW Shear valves	EBW 662 1-1/2"	Manufacturer Approval		
Flexible Double Wall	APT Poly Tech S175SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	TM4236-0/0-0B-S tank sump FRP	Manufacturer Approval		Also using APT LMM3617 UDC's

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	VR794390-420	Manufacturer Approval		
ATG Probe	VR846397-107	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 848480-001	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	EBW705555112CI-GKT	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW-708691921 Defender overfill	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pressurized Dispenser with OPW E85 nozzle, OPW break-a-way swivel , FE STP75AG sub pump	FE Petro STP75AG variable length sub pump	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Encore 700s	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Federal Process E-Seal	Gasolia 1/2 pint can E-seal	Manufacturer Approval		

Correspondence Contact

Submitter Name Rob Schafer
Job Title Construction supervisor
Company PIPECO INC.
Phone Number (563) 344-0700
Email Rob@pipecoinc.com
Contractor License # IL2034

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.