



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 3034795

Facility Name Fuel 24
Address 7814 N. Kickapoo
Edwards, IL 61528
County Peoria
Contact Name John Papenhouse
Phone Number (309) 208-8105

Tank - 5

Tank Material Fiberglass Single Wall
Tank Capacity 13,000
Tank Product E85
Tank Install Date 10/19/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	FLEXWING	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Not Installed STP/Tanktop Sump	no stp sumps STP ABOVE GROUND	Not Applicable		no stp sumps STP ABOVE GROUND
Single Wall UDC Sump	OPW	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
TLS350	VEEDER ROOT	Manufacturer Approval		
ATG Probe	VEEDER ROOT/VR846397-409-10' ALTERNATIVE SS	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin Fueling/STP-MLD+AG	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW/#1	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	VEEDER ROOT/846396 PROBE	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	THE RED JACKET ALCOHOL GAS (AG) STP	Manufacturer Approval		
Dispenser	wayne/ovation	Manufacturer Approval		
Nozzle	opw/11bp-0992	Manufacturer Approval		
Hose	continental/flexsteel futura	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name John Papenhouse
Job Title ENERGY CONSULTANT
Company Ag-Land FS Inc
Phone Number (309) 208-8105
Email jpapenhouse@aglandfs.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.