

**Blended Fuel Compatibility Form**

Facility - 2009036

Facility Name Bill J. Nemeh 2021 Living Trust
Address 7601 S. State Street
Chicago, IL 60619
County Cook
Contact Name Bill & Afrodiet Nemeh
Phone Number (708) 829-1060

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 5,000
Tank Product E-85
Tank Install Date 5/16/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo, B427	Manufacturer Approval		
Single Wall Dispenser Sump	Bravo, B100	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root 846391-507	Lab Certification		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root, TLS-350,	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		dispensers #13/14 & #15/16

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 3112	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	402015912-SVL2-12TPAG33	Manufacturer Approval		
Dispensers #13/14 & #15/16	Wayne EB23/5220D3	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ed Angell

Job Title Project Manager

Company B&K Equipment Company

Phone Number (708) 269-8078

Email ed@bkequip.com

Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.