



Blended Fuel Compatibility Form

Facility - 2006853

Facility Name	K & R Solutions
Address	1 East St. Charles Road Lombard, IL 60148
County	Du Page
Contact Name	Manal Sodagar
Phone Number	(773) 430-6818

Tank - 3

Tank Material	STIP3 Single Wall
Tank Capacity	10,000
Tank Install Date	10/31/1984
Current Product on File	Gasoline - Regular
Newly Reported Product	E85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STIP3 Single Wall	STIP3	Manufacturer Approval	STEEL TANK COMPATABILITY.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FLEXIBLE DOUBLE WALL	NUPI SMART FLEX	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	
Shear Valve	OPW 10 PLUS	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
SINGLE WALL BRAVO TANK TOP SUMP	BRAVO B407	Manufacturer Approval	Bravo Sump Compatibility Statement.pdf	
Single Wall UDC Sump	NUPI	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VEEDER ROOT 846391-408	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE PETRO 403169901 STP-MLD+AG	Manufacturer Approval	FE Petro MLD Compatibility.pdf	
SUMP SENSORS W/ POSITIVE SHUT DOWN	VEEDER ROOT 794380-323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
DOUBLEWALL	OPW 3100	Manufacturer Approval	OPW Belowground Product Compatibility Listing 0715 18.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve East	OPW 71SOM	Manufacturer Approval	OPW 71SOM_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FE PETRO	Manufacturer Approval	FE PETRO STPAPM200-VL2 ff s-0412-60-hz-advanced-pro tection-submersible-turbi ne-pumps-datasheet.pdf	
Dispenser	WAYNE OVATION	Manufacturer Approval	ul-approval-letter-ovation-blender-dispensers.pdf	
Nozzle	OPW 11 A	Manufacturer Approval	OPW 11a-and-11b-automatic -nozzles.pdf	
Hose	GOODYEAR	Manufacturer Approval	Goodyear E85 Ethanol hose .pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		NA

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
PIPE DOPE	GASOILA E SEAL	Manufacturer Approval	Gasoil E-Seal.pdf	

Correspondence Contact

Submitter Name Chris Derro
Job Title PRESIDENT
Company CARDINAL COMPLIANCE LLC
Phone Number (708) 717-2676
Email cderro@cardinalcompliance.net
Contractor License # IL002418

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.