



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2024801

Facility Name True North Location 1984
Address 8226 S. Cass Ave.
Darien, IL 60561
County Du Page
Contact Name Armillio Lopez
Phone Number (815) 577-8575

Tank - 7

Tank Material Tank - Composite Double
Wall Modern Welding Glasteel
II
Tank Capacity 6,000
Tank Product E15
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Modern Welding Glasteel II	Manufacturer Approval	Modern Welding Compatibility.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping Vent	Ameron	Manufacturer Approval	Ameron Pipe Compatibility .pdf	New from Permit Application.
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	UPP Piping for E15.pdf	New from Permit Application.
Shear Valve	OPW	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW, FSTM-4837CR	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	New from Permit Application.
Single Wall UDC Sump	Franklin, DS-3915 Ovation	Manufacturer Approval	Franklin Fueling Compatible Products.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, 794390-409	Manufacturer Approval	Veeder Root Compatibility .pdf	New from Permit Application.
ATG Probe	Veeder Root, 846397-107	Manufacturer Approval	Veeder Root Probe 846397- 1XX.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root, 859080-001	Manufacturer Approval	Veeder Root Compatibility .pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW Edge, 1C-3112P	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW, 71SO-410C	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne Ovation	Wayne Ovation	Manufacturer Approval	Wayne Ovation AX12 Brochu re.pdf	
Submersible Turbine Pump	Franklin, 402797921	Manufacturer Approval	Franklin Fueling Compatible Products.pdf	
Nozzle	OPW, 11BP-8500-E25	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Franklin, FLHFR100009BL	Manufacturer Approval	Franklin Fueling Compatible Products.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Manway Gasket	Modern Welding	Manufacturer Approval	Modern Welding Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
gasoil	gasoil	Manufacturer Approval	Gasoil Compatibility.pdf	

Correspondence Contact

Submitter Name Warren Cherner
Job Title President
Company Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
Phone Number (847) 465-4000
Email warren@metrotank.com
Contractor License # IL102

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.