



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7015146

Facility Name Pilot Travel Center #595
Address 2611 West DeYoung
I-57 & IL Rt. 13, Exit 54 B
Marion, IL 62959
County Williamson
Contact Name Dani Harper
Phone Number (618) 993-2697

Tank - 24

Tank Material Fiberglass Double Wall
Tank Capacity 15,000
Tank Install Date 10/11/2011
Current Product on File Diesel Fuel
Newly Reported Product B-99

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	Xerxes Compatible.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	DUALOY 3000LCX.pdf	
Shear Valve	OPW	Manufacturer Approval	SHEAR VALVE.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	NEF	Lab Certification	NEF SUMP.pdf	
Blending Sump	PCI CS-TS72304	Lab Certification	PCI BLENDING SUMP.pdf	
Double Wall UDC Sump	NEF	Lab Certification	NEF SUMP.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 0794380-430	Lab Certification	INTERSTITIAL SENSOR FIBER GLASS TANK.pdf	
ATG Probe	VEEDER ROOT 846397-109	Lab Certification	Veeder+Root+Bio+Compatibl e+MAG+and+Sump+Sensor.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping Sump Sensors Not Regulated in Single Wall STP/Tanktop Sump	VEEDER ROOT	Lab Certification	SUMP SENSOR POSITIVE SHUT DOWN.pdf	
Sump Sensor with positive shutdown in Blending Sump	veeder root	Lab Certification	SUMP SENSOR POSITIVE SHUT DOWN.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	opw	Lab Certification	OPW 1-2100 SPILL BUCKET.p df	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 71so-410cb	Lab Certification	DROP TUBE 71SO.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	GORMAN RUPP GHS2JP3-B/S1	Lab Certification	b99+Gorman+Rupp PUMP.pdf	
Dispenser	ENCORE 300	Lab Certification	FUEL DISPENSER.pdf	
Nozzle	opw14HC-0400-XC	Lab Certification	BIO NOZZLE.pdf	
Hose	CONTINENTAL 559N	Lab Certification	HoseSelect_FlexsteelFutura.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
SEAL/GASKET	GORMAN RUPP	Lab Certification	GORMAN RUPP.pdf	

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

SAMANTHA HUNTER

customer service coordinator

NEUMAYER EQUIPMENT

(314) 772-4501

testing@neumayerequipment.com

IL1502

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.