

**Blended Fuel Compatibility Form**

Facility - 1046084

Facility Name Elizabeth Fast Stop
Address 1487 US Hwy 20 West
Elizabeth, IL 61028
County Jo Daviess
Contact Name Shellie Callan
Phone Number (815) 858-9300

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E-85
Tank Install Date 3/11/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval		B4 Series Tank Sump
Single Wall UDC Sumps	Franklin Fueling	Manufacturer Approval		All listed sumps in attachment are E-85 compatible. Part number for UDC sumps in...

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling - TS-ULS	Manufacturer Approval		
ATG Probe	Franklin Fueling - TSP-LL2	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling - TS-LS500/4	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Franklin Fueling - TSP-EIS	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling - 705-492-12BLK	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling - 708692922 Defender	Manufacturer Approval		
Overfill Alarm	Franklin Fueling - TS-RA1	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispensers	Gilbarco Encore 700S	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Gordon Williams By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title Energy Department Manager
Company Gordon Williams
Phone Number (815) 541-3160
Email gwilliams@stephensonfs.com