



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2008464

Facility Name Suha Fullerton Citgo
Address 4900 W. Fullerton
Chicago, IL 60639
County Cook
Contact Name Imran Moten
Phone Number (312) 745-0480

Tank - 9

Tank Material Tank - Fiberglass Double
Wall XERXES
Tank Capacity 4,000
Tank Product E-85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	Zerxes Tank Compa...	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - ...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	B407	Manufacturer Approval	Bravo Sump Compat...	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	794380-345	Manufacturer Approval	Veeder Root Senso...	From Permit Application
ATG Probe	846391-407	Manufacturer Approval	Veeder Root E85 p...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	403169901	Manufacturer Approval	FE Petro MLD Comp...	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	794380-323	Manufacturer Approval	Veeder Root Senso...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100 Series	Manufacturer Approval	OPW Belowground P...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
		Manufacturer		From

Overfill Drop Tube Valve Compatibility Item	71SOM Model/Manufacturer	App Compatibility Method	OPW 71SOM_Overfil... Documentation	Permit Comment
---	------------------------------------	------------------------------------	--	--------------------------

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
3+1 (E-85)	Wayne Ovation	Manufacturer Approval	ul-approval-lette...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
N/A	N/A	Not Applicable		Gaskets and seals included in all approved units by manufacturer.

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	GASOILA E SEAL	Manufacturer Approval	Gasola E-Seal.pd...	

Correspondence Contact

Submitter Name Chris Derro

Job Title President

Company Cardinal Compliance LLC

Phone Number (708) 452-8620

Email cderro@cardinalcompliance.net

Contractor License # IL002418

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.