

**Blended Fuel Compatibility Form**

Facility - 2046777

Facility Name Roux Gas Station
Address 7051 S Western
Chicago, IL 60636
County Cook
Contact Name Naser Odeh
Phone Number (708) 769-9010

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 1/31/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall Tank	Containment Solutions	Manufacturer Approval	CSI+Compatibility+Statement (2).pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall pipe	ameron	Manufacturer Approval	NOV LCX pipe and fittings .pdf	Added as part of permit
Flexible Double Wall pipe	Franklin Fueling APT 150SC	Manufacturer Approval	franklin apt pipe.pdf	Added as part of permit
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI+UL+LETTER+-+COMPATIBILITY+(1).pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	OPW, Pisces series	Manufacturer Approval	opw all products.pdf	
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	CSI+Compatibility+Statement (3).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval	veeder root probes.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, 794380-345	Manufacturer Approval	Veeder+Root+Sensor+Compatibility+Statement (1).pdf	Existing in tank interstitial space

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin Fueling MLD	Manufacturer Approval	FE+Petro+MLD+Compatibility.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	Veeder+Root+Sensor+Compatibility+Statement (1).pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 101-BG	Manufacturer Approval	OPW+Belowground+Product+Compatibility+Listing+071518.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	OPW+71SOM_Overfill_Prevention_Valve.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	FE Petro	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass pipe adhesive	Ameron	Manufacturer Approval	ameron fiberglass pipe.pdf	

Correspondence Contact

Submitter Name Ed Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.