



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2010562

Facility Name Bucky's Express #6534
Address 1420 E. Ogden Avenue
Naperville, IL 60563
County Du Page
Contact Name Deno Scali
Phone Number (630) 357-9397

Tank - 11

Tank Material Tank - Fiberglass Double Wall
XERXES
Tank Capacity 8,000
Tank Product E15
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Tanks.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	OPW Compatibility Matrix.pdf	New from Permit Application.
Ball Valves	Jomar	Manufacturer Approval	15+Jomar+Ball+Valve (1).pdf	New from Permit Application.
Flex Connector Steel	HoseMaster	Manufacturer Approval	flexibleconnectorsystems (2).pdf	New from Permit Application.
Fiberglass Single Wall Piping single wall vent	Ameron Fiberglass 4000 L	Manufacturer Approval	Ameron Piping.pdf	New from Permit Application.
Shear Valves	OPW 10PLus	Manufacturer Approval	OPW Shear Valve.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes	Manufacturer Approval	Xerxes Sumps.pdf	New from Permit Application.
OPW Loop System	OPW	Manufacturer Approval	OPW Compatibility Matrix.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root TLS-450Plus	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	New from Permit Application.
ATG Probe	Veeder Root Tank Probe	Manufacturer Approval	Veeder Root Probe & Float .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	VR+PLLD+Fuel+Compatibility.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Manufacturer Approval	OPW Compatibility Matrix.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW	Manufacturer Approval	OPW Overfill Prevention Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro	Manufacturer Approval	FE Petro Submersible Pump .pdf	
Dispenser	Wayne Ovation	Manufacturer Approval	Wayne Dispenser Meter.pdf	
Nozzle	OPW	Manufacturer Approval	OPW Compatibility Matrix.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia	Gasolia	Manufacturer Approval	Gasolia.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia	Gasolia	Manufacturer Approval	Gasolia.pdf	

Correspondence Contact

Submitter Name Nate Meyer
Job Title Director of Sales & Construction
Company Stenstrom Petroleum Services Group
Phone Number (815) 209-6640
Email natem@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.