



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2047012

Facility Name Lenny's Gas N Wash
Yorkville, LLC.
Address 4100 N Bridge Street
Yorkville, IL 60560
County Kendall
Contact Name Len McEnery
Phone Number (708) 444-0117

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 4/9/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	Xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
udc	Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Bravo	Lab Certification	Bravo Sumps.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	veeder root 794390-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-003	Lab Certification	Veeder Root Sensors.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Lab Certification	Veeder Root Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling	Lab Certification	Defender spill bucket Franklin.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw	Lab Certification	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Gilbarco	Lab Certification	Gilbarco Dispensers.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Caps and Rings	veeder root	Lab Certification	Cap and Ring E85 Compatib ility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gaseola e seal	Lab Certification	Gasoila Pipe dope.pdf	

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Stephen Kryl

Project Manager

Anderson Pump Service, Inc.

(708) 243-9081

Steve@andersonpump.com

IL002275

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.