

**Blended Fuel Compatibility Form**

Facility - 2021626

Facility Name Thornton's #19
Address 1118 Touhy Avenue
Park Ridge, IL 60068
County Cook
Contact Name Daniel
Phone Number (312) 451-3621

Tank - 6

Tank Material Fiberglass Single Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 4/30/1999

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks.pdf	We did not install tank. Your records show Containment solutions

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Ameron Dualoy Piping.pdf	We did not install lines. Your records show Ameron LCX.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP/Tank Top Sump	Containment Solutions SW RTS (WT34) 42-4	Manufacturer Approval	Containment Solutions Tank and Sumps.pdf	Per install sheet in 2015 from owner
UDCs	Bravo B-1000-HE	Manufacturer Approval	Bravo Sumps.pdf	Per install sheet in 2015 from owner

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Automatic Tank Gauging	Veeder Root 846391-407	Manufacturer Approval	ATG Probe.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Leak Detection	Veeder Root PLLD	Manufacturer Approval	VR PLLD.pdf	
Sump Sensors	Veeder Root 794380-323	Manufacturer Approval	Veeder-Root Sensor Compatibility.pdf	Installed in UDCs and STP Sump
Electronic Pressurized Line Leak Detection	Veeder Root DPPLD	Manufacturer Approval	VR+PLLD+Fuel+Compatibility.pdf	Replacing - Electronic Pressurized Line Leak Detection from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin 705555101CI-GKT	Manufacturer Approval	Franklin+SB.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro	FE Petro IST-M-R-VS4-VL2-17	Manufacturer Approval	Franklin STP.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Amber Pena
Job Title Service Manager
Company Stenstrom Petroleum Services Group
Phone Number (815) 398-6250
Email amberp@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.