



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7017720

Facility Name ROC One Stop
Address 1201 W. Main
West Frankfort, IL 62896
County Franklin
Contact Name Chelsea Spears
Phone Number (618) 268-4722

Tank - 14

Tank Material Composite Double Wall
Tank Capacity 8,000
Tank Install Date 11/9/2017
Current Product on File E-85
Newly Reported Product E-15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall Tank	Glasteel II	Manufacturer Approval	Modern E10-E100.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall Product Line	Ameron Dualoy 3000/LCX	Lab Certification	NOV HIGH BLEND.pdf	
Flex Hose	Hose Master FSMM 1.5	Lab Certification	HOSE MASTER FSMM.pdf	
Shear Valve	OPW 10 Series	Manufacturer Approval	OPW 10 SHEAR VALVE.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerged Pump Sump	Franklin Fueling APT TSM	Manufacturer Approval	APT SUMPS.pdf	
Under Dispenser Sump	OPW Pisces	Manufacturer Approval	OPW SUMPS.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensor	Franklin Fueling (Incon) FMP-ULS	Manufacturer Approval	INCON FMP-ULS-WEST FRANKF ORT.pdf	
ATG Probe	Veeder Root 846391-1XX	Manufacturer Approval	VR Probe-109.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	VR PLLD.pdf	
Non-Discriminating Sump Sensor	Veeder Root 794380-208	Manufacturer Approval	VR Sump Sensor 208.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100	Manufacturer Approval	OPW 2100-3100-61SOM.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61SOM	Manufacturer Approval	OPW 2100-3100-61SOM.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	STP AG 150	Manufacturer Approval	FE Petro STP150AG.pdf	
Dispenser	Wayne Ovation EB23	Lab Certification	Wayne Ovation EB.pdf	
Dispenser Hoses	Contitech Flexsteel Futura Ethan-All	Manufacturer Approval	Contitech E85.pdf	
Breakaway	OPW 66V-0492	Manufacturer Approval	OPW 66V-0492.pdf	
Swivel	OPW 241TPS-0492	Manufacturer Approval	OPW 241TPS-0492.pdf	
Nozzles	OPW 11BP	Manufacturer Approval	OPW 11BP.pdf	
Nozzles	OPW 21GE	Manufacturer Approval	OPW 21GE.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Adam Laws
Job Title Sales Rep
Company Mid-South Steel
Phone Number (573) 335-5529
Email adam@midsouthsteel.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.