

**Blended Fuel Compatibility Form****Facility - 2043141**

Facility Name Woodman's Gas/Lube & Car Wash
Address 150 Hansen Boulevard
North Aurora, IL 60542
County Kane
Contact Name Victor Samperio
Phone Number (630) 754-8382

Tank - 2

Tank Material Fiberglass Single Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 5/22/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks and Sumps.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	A.O. Smith	Manufacturer Approval	Smith Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC Containment Sump	Franklin Fueling	Manufacturer Approval	Franklin Fueling Sumps.pdf	
Single Wall STP/Tanktop Sump	Bravo Fiberglass Systems	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
InCon	EVO 600	Manufacturer Approval	Franklin Fueling -ULS-HFS-LL3-E85-8-2-19.pdf	
ATG Probe	EVO 600 Tank Probe FMP-LL3	Manufacturer Approval	Franklin Fueling -ULS-HFS-LL3-E85-8-2-19.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sump Sensor with positive shutdown	EVO ULS Sensor	Manufacturer Approval	FFS-0635 Sensors Datasheet.pdf	New from Permit Application.
Electronic Pressurized Line Leak Detection	InCon	Manufacturer Approval	FFS-0263 Electronic Line Leak Detection Datasheet.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling	Manufacturer Approval	Franklin Fueling Spill Buckets and Drop Tubes.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube	Franklin Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	
Overfill Alarm	InCon	Manufacturer Approval	Franklin+Sump+Approval.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne Ovation	B23/4	Manufacturer Approval	Wayne Dispenser Meter.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolia	Manufacturer Approval	Gasolia.pdf	

Correspondence Contact

Submitter Name Nate Meyer
Job Title Director of Sales & Construction
Company Stenstrom Petroleum Services Group
Phone Number (815) 209-6640
Email natem@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.