

**Blended Fuel Compatibility Form**

Facility - 6045586

Facility Name Love's Travel Stop #583
Address 8690 Richter School Rd.
New Baden, IL 62265
County Clinton
Contact Name Bryan Taulbee
Phone Number (405) 834-0311

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 6/13/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions-Com patibility (2) B99 & E85. pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC Sumps	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	V-R_794380-345_Intersitia lSensor.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	V-R_848480-003_PLLD.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval	V-R_794380-321_SumpSensor .pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	below-ground-products-fue l-compatibility-matrix-20 18.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling	Manufacturer Approval	Defender Overfill Prev. Valve B99 & E85.pdf	
Overfill Alarm	Veeder Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Veeder Root	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Anthony Mannino	
Job Title	Project Manager	
Company	Illinois Oil Marketing Equipment, Inc.	
Phone Number	(309) 202-0792	
Email	amannino@iome.com	
Contractor License #	IL1293	