

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 1011925

Facility Name Beck Oil Company
Address 605 West Peru Street
Princeton, IL 61356
County Bureau
Contact Name Candice Alvarado
Phone Number (815) 875-6451

Tank - 8

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-15
Tank Install Date 10/26/2017

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		6,000 E15 tank DW Containment Solutions

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		APT 1-3/4" XP flexible pipe
Fiberglass Double Wall	Ameron Dualoy 3000/L	Manufacturer Approval		
Flex Connector Steel	FF15X18HWM346	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump and APT LMM3617 UDC's	602402922 42" collar mnt sump no bottom	Manufacturer Approval		Also using APT LMM3617 UDC's

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-323	Manufacturer Approval		
ATG Probe	Veeder Root 846396-107	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Manufacturer Approval		
Sump sensor	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW#1	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
EBW Defender	EBW-708691921 Defender overfill	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pressurized Dispenser with OPW E85 nozzle, OPW break-a-way swivel , Husk	FE Petro STP75AG variable length sub pump	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Rob Schafer	
Job Title	Construction supervisor	
Company	PIPECO INC.	
Phone Number	(563) 344-0700	
Email	Rob@pipecoinc.com	
Contractor License #	IL2034	