

**Blended Fuel Compatibility Form**

Facility - 2045460

Facility Name Thornton's, Inc. #315
Address 2609 N. Farnsworth Ave.
Aurora, IL 60505
County Kane
Contact Name Gustavo Zuleta
Phone Number (630) 820-2075

Tank - 2

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 4/24/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions Com patibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	10P-0152	Manufacturer Approval	14+OPW+Shear+Valve (1).pd f	New from Permit Application.
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Piping Compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Under Dispenser Containment	Bravo	Manufacturer Approval	Bravo RED UDC Sump Compat ibility.pdf	
UST	Containment Solutions	Manufacturer Approval	Containment Solutions Com patibility.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root	Manufacturer Approval	Probe Compatibility.pdf	
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root	Manufacturer Approval	Position+Sensitive+Sensor .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Electronic Leak Sensor Co mpatibility.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval	Position+Sensitive+Sensor .pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Manufacturer Approval	EBW SSH Fuel Compatibilit y_DoubleCheck Defender.pd f	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	Overfill Valve and Spill Bucket Compatibility.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	PMAG-VS4 FE Petro	Manufacturer Approval	STP Compatible.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Nick Bugajsky
Job Title Project Manager
Company Stenstrom Petroleum Services Group
Phone Number (630) 606-0996
Email nickb@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.