



Blended Fuel Compatibility Form

Facility - 2021623

Facility Name	Thornton's #16
Address	190 E. Lake Street Bloomington, IL 60108
County	Du Page
Contact Name	Brian Voytovick
Phone Number	(630) 894-2546

Tank - 15

Tank Material	Fiberglass Brine Filled Double Wall
Tank Capacity	6,000
Tank Product	E-85
Tank Install Date	9/27/2011

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Xerxes	Manufacturer Approval		
Single Wall UDC Sumps	Containment Solutions	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval		
ATG Probe	Veeder Root	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro	PMAAG-VS4 FE Petro	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Brian Carben

Job Title Techincian

Company Beacon SSI

Phone Number (708) 638-0390

Email Brian.carben@beaconssi.com

Contractor License # IL002336

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.