

**Blended Fuel Compatibility Form**

Facility - 2045977

Facility Name Speedway Store #6207
Address 1495 East Wilson St.
Batavia, IL 60510
County Kane
Contact Name Store Manager
Phone Number (630) 406-0241

Tank - 1

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 10/13/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	Equipment-Compatibility-R FA.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall UDC/Dispenser sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veedor Root/846931-507	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veedor Root/794380-345	Manufacturer Approval	577013-750-13_Solid-State Alternative Ethanol Fluid Interstitial Sensor_for_Double-Wall_Fiberglass_Tanks.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/859080-001/002	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root/794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW-1C2100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	61SOM & 71SOM Series	Manufacturer Approval	OPW Compatibility Matrix. pdf	Replacing from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco	Encore Series	Manufacturer Approval	Encore Flex Fuel Dispenser_Gilbarco Veeder-Root. pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Keith Duda

Job Title Project Manager

Company Anderson Pump Service, Inc.

Phone Number (708) 560-5590

Email Keith@Andersonpump.com

Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.