



Blended Fuel Compatibility Form

Facility - 2047540		Tank - 4	
Facility Name	Casey's General Stores #6940	Tank Material	Fiberglass Double Wall
Address	1 S 034 Winfield Road Winfield, IL 60187	Tank Capacity	8,000
County	Du Page	Tank Product	E85
Contact Name	Lee Lytle	Tank Install Date	1/19/2023
Phone Number	(515) 446-6231		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	Xerxes Fuel Compatibility re Ethanol & BioDiesel Letter E-10.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval	FFS-0524 XP Flexible Pipe work Datasheet.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Franklin tank sump, part #TSM-W-4736 and Franklin dispenser sump, part #LMD-2715	Franklin Fueling	Manufacturer Approval	Franklin Fueling Compatible Products.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root, Model #846391-607	Manufacturer Approval	Veeder Root Compatibility .pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, part #794380-345	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root, Model #794380-323	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin, EBW defender overspill, part #705556111BLK	Manufacturer Approval	Franklin Fueling Compatible Products.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin, part #708691922	Manufacturer Approval	Franklin Defender Series OPV Datasheet.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro Submersible	STPAG75-VL2	Manufacturer Approval	FE Petro E15 Submersible.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasket	Xerxes	Manufacturer Approval	Xerxes Fuel Compatibility re Ethanol & BioDiesel Letter E-10.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoil	Manufacturer Approval	Gasoil Compatibility.pdf	

Correspondence Contact

<p>Submitter Name Warren Cherner</p> <p>Job Title President</p> <p>Company Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company</p> <p>Phone Number (847) 465-4000</p> <p>Email info@metrotank.com</p> <p>Contractor License # IL102</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
---	--