

**Blended Fuel Compatibility Form**

Facility - 1011924

Facility Name Beck Oil
Address 1838 North Main Street
Princeton, IL 61356
County Bureau
Contact Name Jill Waldo
Phone Number (815) 875-9034

Tank - 15

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 12/21/2011

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall 6,000 Containment solution Tank	CSI-6,000 DW UST	Manufacturer Approval		Containment solution tank is compatible per MFG.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall Piping	APT P175 pipe 1 3/4" flexible	Manufacturer Approval		APT 1 3/4" pipe is E85 approved
EBW 662 1 1/2" shear valve	EBW 662 1 1/2" shear valve	Manufacturer Approval		EBW shear valve is also E85 approved

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall UDC	APT UDC LMN-3617 UL-2447	Manufacturer Approval		APT Gilbarco dispenser sump is e85 approved
APT TSM 4736 poly sump	APT TSM-4736 poly sump	Manufacturer Approval		E85 approved

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	INCON Interstitial Sensor	Manufacturer Approval		
ATG Probe	INCON 5000 TSP-LL2	Manufacturer Approval		
INCON EVO 5000 system	EVO 5000	Manufacturer Approval		E85 memo

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	INCON	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	INCON 5000	Manufacturer Approval		
Mag probes TSP-LL2	TSP-LL2, ULS sump sensors, TSP E15 annular sensor	Manufacturer Approval		Compatibility documentation

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1SC-2100-EVR	Manufacturer Approval		
OPW 5 gallon	OPW 1-SC-2100-EVR	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	EBW Franklin Fueling	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Encore 700 Flexible Fuel Dispensers	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Robert Schafer
Job Title Installer/ Supervisor
Company PIPECO INC
Phone Number (563) 529-8502
Email rob@pipoecoinc.com
Contractor License # IL2034

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.