



### Blended Fuel Compatibility Form

Facility - 5045654

<b>Facility Name</b>	Tri-County F.S. Inc.
<b>Address</b>	1000 S. June Street County Road and June Street Jerseyville, IL 62052
<b>County</b>	Jersey
<b>Contact Name</b>	Dave Lewis
<b>Phone Number</b>	(618) 498-5534

Tank - 2

<b>Tank Material</b>	Fiberglass Double Wall
<b>Tank Capacity</b>	12,000
<b>Tank Product</b>	E-85
<b>Tank Install Date</b>	8/7/2014

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Lab Certification	Containment Solut...	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Lab Certification	P-150-SC approval...	
Shear Valve	EBW 662 AGB	Manufacturer Approval	FF shear valves.p...	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT TSM-4542	Manufacturer Approval	APT SW Polyethyl...	Does not normally contain E85
Single Wall Fiberglass UDC (Dispensers 1,2 3,4)	Petroleum Containment Inc Model DP174360	Lab Certification	UL Standards.pdf	UL 2447 listed, Does not normally contain E85

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-410 (SS)	Manufacturer Approval	Veeder Root compo...	Replacement for existing Veeder Root 846390-410 (Aluminum)
Tank Interstitial sensor	Veeder Root 0794380-345	Manufacturer Approval	VR 0794380-345 se...	On Order to replace existing 0794390-409 installed sensor. Interstice does not ...

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	Veeder Root compo...	These are on order to replace 794380-208 sensors installed
Mechanical Line Leak Detector	Franklin Fueling MLD+AG	Lab Certification	FE Petro MLD+AG.p...	

### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 W/EMCO A1005-505SS SS Liner	Manufacturer Approval	EMCO A1005-505C.p...	On order to upgrade existing spill bucket

### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling 708691922 Defender AGB compatible	Manufacturer Approval	FF Defender OPV.p...	From Permit Application to replace existing aluminum drop tube and vent ball flo...
Ball Float Vent Valve	EBW 308	Not Applicable		From Permit Application To be removed upon OPV installation

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	FE Petro STPAG-075	Manufacturer Approval	FF STP.pdf	Existing FE Petro STP is being upgraded to AG specs.
Fuel Dispensers	Gilbarco NJ0 Flex Fuel	Manufacturer Approval	Gilbarco Flex Fue...	
Nozzles	OPW 21GE	Lab Certification	OPW 21Ge Nozzle.p...	
Hose Swivels	OPW 241TPS-0492	Manufacturer Approval	OPW E-85 swivels....	
Break Aways	OPW 66V-0492	Manufacturer Approval	OPW HH componets....	
Hoses	Franklin Fueling FLXE 200900 and FLXE 200009	Lab Certification	FF E85 hoses.pdf	UL330A

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

**Correspondence Contact**

**Submitter Name** Mike OConnell

**Job Title** Vice President

**Company** Pemco Service Company, Inc.

**Phone Number** (309) 828-6134

**Email** pemco2@frontier.com

**Contractor License #** IL1224

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.