



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 5003096

Facility Name West End Food Mart
Address 416 S. O'Bannon Street
Raymond, IL 62560
County Montgomery
Contact Name Gerald Wagahoff
Phone Number (217) 229-3331

Tank - 6

Tank Material Composite Double Wall
Tank Capacity 8,000
Tank Install Date 4/29/2025
Current Product on File Gasoline - Mid-grade
Newly Reported Product E15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Modern Welding Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	EBW	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	PCI	Manufacturer Approval		
Single Wall UDC Sump	OPW	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval		
ATG Probe	Veeder Root	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112D	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flex connector	Franklin Fueling	Manufacturer Approval		
Submersible Turbine Pump	Red Jacket	Manufacturer Approval		
Suction Pump	N/A	Not Applicable		There are no suction pumps on the facility
Dispenser	Gilbarco 700S	Manufacturer Approval		
Nozzle	OPW 11BP	Manufacturer Approval		
Hose	VST V34ff	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping	Dualoy	Manufacturer Approval		Gaskets and seals are covered under the manufacturers paperwork for piping

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe dope and adhesives	Gasolila, Ameron	Manufacturer Approval		

Correspondence Contact

Submitter Name Tom Oltman
Job Title General Manager
Company Total Petroleum Service Co.
Phone Number (309) 694-8224
Email Tom.Oltman@TotalPetroleum.net
Contractor License # IL1079

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.