



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 3017560

Facility Name Casey's General Store
#2380

Address 103 6th Ave. East.
Andalusia, IL 61232

County Rock Island

Contact Name Corinna Kellerman

Phone Number (309) 798-2544

Tank - 7

Tank Material Fiberglass Double Wall

Tank Capacity 8,000

Tank Product E-85

Tank Install Date 11/29/2017

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		
Flex Connector Steel	Flexing	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling	Manufacturer Approval		
Franklin fueling poly UDC	Franklin Fueling	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeter Root TLS350 Plus	Manufacturer Approval		
ATG Probe	Veeter Root TLS350 Plus	Manufacturer Approval		

Release Detection Piping Equipment


Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeter Root PLLD	Manufacturer Approval		
Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeter Root TLS350 Plus	Manufacturer Approval		

Spill Prevention Equipment


Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling Defender 5 Gallon SW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW Franklin Fueling Overfill valve	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Encore 700 Flexible Fuel Dispensers	Lab Certification		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact	
Submitter Name	Robert Schafer
Job Title	Installer
Company	Pipeco Inc
Phone Number	(563) 529-8502
Email	rob@pipecoinc.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.