



### Blended Fuel Compatibility Form

Facility - 2029682

**Facility Name** Administration Building  
**Address** 2700 Ogden Avenue  
Downers Grove, IL 60515  
**County** Du Page  
**Contact Name** John Pozdol  
**Phone Number** (630) 241-6800

Tank - 2

**Tank Material** Fiberglass Brine Filled Double Wall  
**Tank Capacity** 10,000  
**Tank Product** E-85  
**Tank Install Date** 7/8/1992

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass underground storage tank	Owens Corning	Manufacturer Approval		

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	OPW	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Owens Corning	Manufacturer Approval		
Single Wall UDC Sump	OPW Pisces	Manufacturer Approval		

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Veeder Root 794380-303	Manufacturer Approval		Please see second page of attached
ATG Probe	Veeder Root 846391-407	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100	Manufacturer Approval		

**Overfill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
overfill drop tube	OPW 71SOM-412C	Manufacturer Approval		

**Pump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Red Jacket STPAGR75-VL2	Manufacturer Approval		

**Gaskets & Seals Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

**Joint Dopes & Adhesives Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

**Correspondence Contact**

**Submitter Name** Jason Reed  
**Job Title** construction Manager  
**Company** Stenstrom Petroleum  
**Phone Number** (630) 878-6354  
**Email** jasonre@rstenstrom.com  
**Contractor License #** IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.