

**Blended Fuel Compatibility Form**

Facility - 6045582

**Facility Name** Love's Travel Stop #578  
**Address** 9191 State Route 140  
Hamel, IL 62046  
**County** Madison  
**Contact Name** Kyle Collins  
**Phone Number** (405) 834-0311

Tank - 2

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 12,000  
**Tank Install Date** 5/22/2014  
**Current Product on File** Gasoline - Regular  
**Newly Reported Product** E-15

**Tank Equipment**

| Compatibility Item     | Model/Manufacturer    | Compatibility Method  | Documentation                                    | Comment |
|------------------------|-----------------------|-----------------------|--------------------------------------------------|---------|
| Fiberglass Double Wall | Containment Solutions | Manufacturer Approval | containment solutions bio fuel-compatibility.pdf |         |

**Piping Equipment**

| Compatibility Item     | Model/Manufacturer     | Compatibility Method  | Documentation                                         | Comment |
|------------------------|------------------------|-----------------------|-------------------------------------------------------|---------|
| Fiberglass Double Wall | Ameron Dualoy 3000/LCX | Manufacturer Approval | NOV - Fuel compatibility Dualoy 3000L 3000LCX -3. pdf |         |

**Containment Sump Equipment**

| Compatibility Item           | Model/Manufacturer | Compatibility Method  | Documentation                       | Comment |
|------------------------------|--------------------|-----------------------|-------------------------------------|---------|
| Single Wall STP/Tanktop Sump | Bravo / B400       | Manufacturer Approval | Bravo - Sumps Alternative Fuels.pdf |         |
| UDC                          | Bravo/B200         | Manufacturer Approval | Bravo - Sumps Alternative Fuels.pdf |         |

**Release Detection Tank Equipment**

| Compatibility Item                                 | Model/Manufacturer  | Compatibility Method  | Documentation                                                  | Comment |
|----------------------------------------------------|---------------------|-----------------------|----------------------------------------------------------------|---------|
| Non-Discriminating Interstitial Monitoring Sensors | Veeder Root/ 409    | Manufacturer Approval | Veeder Root 577013-750_AG -1.pdf                               |         |
| ATG Probe                                          | Veeder Root/ 846396 | Manufacturer Approval | Veeder Root 577014-449-01_Aluminum_Mag_Plus_In-Tan k_Probe.pdf |         |

**Release Detection Piping Equipment**

| Compatibility Item                                                                    | Model/Manufacturer          | Compatibility Method  | Documentation                          | Comment                                                                |
|---------------------------------------------------------------------------------------|-----------------------------|-----------------------|----------------------------------------|------------------------------------------------------------------------|
| Siphon Bar                                                                            | Veeder Root-PLLD 848480-001 | Manufacturer Approval | Veeder-Root - compatibility matrix.pdf | There is no pressurized piping for this tank it is a siphon only tank. |
| Electronic Pressurized Line Leak Detection                                            | 848480-003                  | Manufacturer Approval | Veeder-Root - compatibility matrix.pdf |                                                                        |
| Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Veeder Root/208             | Manufacturer Approval | Veeder Root 577013-750_AG .pdf         |                                                                        |

**Spill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation                      | Comment |
|--------------------------|--------------------|-----------------------|------------------------------------|---------|
| Single Wall Spill Bucket | OPW 101BG Series   | Manufacturer Approval | OPW - compatibility matrix (1).pdf |         |

**Overfill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer     | Compatibility Method  | Documentation                                                  | Comment |
|--------------------------|------------------------|-----------------------|----------------------------------------------------------------|---------|
| Overfill Alarm           | Veeder Root/790091-001 | Manufacturer Approval | Veeder Root 577014-449-01_Aluminum_Mag_Plus_In-Tan k_Probe.pdf |         |
| Overfill Drop Tube Valve | OPW/61SOM              | Manufacturer Approval | OPW - compatibility matrix (1).pdf                             |         |

**Pump Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation                | Comment |
|--------------------------|--------------------|-----------------------|------------------------------|---------|
| Submersible turbine pump | Red Jacket/ P200U1 | Manufacturer Approval | Red Jacket Compatibility.pdf |         |

**Gaskets & Seals Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

**Joint Dopes & Adhesives Equipment**

| Compatibility Item | Model/Manufacturer | Compatibility Method  | Documentation                                         | Comment |
|--------------------|--------------------|-----------------------|-------------------------------------------------------|---------|
| Pipe Dope          | Gasola E-Seal      | Manufacturer Approval | Gasola - E seal E20.pdf                               |         |
| Piping Adhesive    | Ameron/PSX20       | Manufacturer Approval | NOV - Fuel compatibility Dualoy 3000L 3000LCX -3. pdf |         |

**Correspondence Contact**

**Submitter Name** kevin nickell  
**Job Title** env divs mgr  
**Company** loves travel stops  
**Phone Number** (405) 380-5796  
**Email** kevin.nickell@loves.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.