



### Blended Fuel Compatibility Form

Facility - 2039729

**Facility Name** Harrison Street, Inc.  
**Address** 4751 W. Harrison  
Chicago, IL 60644  
**County** Cook  
**Contact Name** Nabil Ahmed  
**Phone Number** (773) 287-3700

Tank - 3

**Tank Material** Fiberglass Single Wall  
**Tank Capacity** 5,000  
**Tank Product** E85  
**Tank Install Date** 5/5/2000

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	NOV	Manufacturer Approval	FG DW by NOV.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW, 10P-0152E85	Manufacturer Approval	opw+shear+valves.pdf	
Other Pump	Submersible	Manufacturer Approval	franklin+stp.pdf	New from Permit Application.
Shear Valves	OPW, 10P-0152E85	Manufacturer Approval	opw+shear+valves.pdf	New from Permit Application.
Fiberglass Single Wall Piping	NOV	Manufacturer Approval	Ameron fibre glass single wall.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dingle wall Stp sump	Franklin fueling/TSM 4542	Manufacturer Approval	UL2447.pdf	
Under Dispenser containment	OPW Pisces	Manufacturer Approval	png2pdf.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/ Mag probe for alternate fuels	Manufacturer Approval	Mag probe.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Fe-petro/MLD	Manufacturer Approval	FFS-0391+MLD++Mechanical+Leak+Detectors+Datashet.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling, 7054740X	Manufacturer Approval	e85+franklin+all.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EMCO/A1100 ("E" variant) A1100EVR ("E" variant)	Manufacturer Approval	Emco Droptube.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin 4020159	Manufacturer Approval	franklin+stp.pdf	
Dispenser	Gilbarco® Encore® 700 S or S dispensers	Manufacturer Approval	Encore_flex_fuel.pdf	
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval	OPW-Fuel+Compatibility+Nozzle+(Above+Ground).pdf	
Hose	VST	Manufacturer Approval	VST-ENVIRO-LOC-Flex-Fuel-Hose_Press-Release-042021 .pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Haibat KHAN  
**Job Title** Manager  
**Company** American Petroleum Solutions LLC  
**Phone Number** (909) 312-9449  
**Email** apetro.office@gmail.com  
**Contractor License #** IL002454

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.