

**Blended Fuel Compatibility Form**

Facility - 7043712

Facility Name Pilot Travel Center #482
Address 4610 Broadway
Mount Vernon, IL 62864
County Jefferson
Contact Name Aubrey Carter
Phone Number (618) 244-1216

Tank - 5

Tank Material Composite Double Wall
Tank Capacity 20,000
Tank Product E15
Tank Install Date 8/9/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	ACT 100	Manufacturer Approval	ACT-100-U Tanks _ Modern Welding.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW/E401	Manufacturer Approval	Equipment-Compatibility.p df for E15 OPW dispenser sumps.pdf	
Fiberglass Double Wall	Ameron	Manufacturer Approval	ameron dualoy 3000 lcx da ta sheet.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW	Manufacturer Approval	Equipment-Compatibility.p df for E15 OPW dispenser sumps.pdf	
Single Wall UDC Sump	OPW/flexworks	Manufacturer Approval	Equipment-Compatibility.p df for E15 OPW dispenser sumps.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846390-109	Manufacturer Approval	VR+Probe-109.pdf	
Non-Discriminating Interstitial Monitoring Sensors With Monitor	VR-0794390-409	Manufacturer Approval	VR-0794390-409 577013- 750 -12_AE Veeder root inters titial monitor proof.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Line leak detector	FE Petro STP-MLD+AG	Manufacturer Approval	_assets_products_document s_FE-Petro-mechanical-lea k- detectors.pdf	
Mechanical Pressurized Line Leak Detection	VEEDER ROOT	Lab Certification	_assets_products_document s_FE-Petro-mechanical-lea k- detectors.pdf	
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 208	Manufacturer Approval	577013-750-08_Piping_Sump _Sensor.pdf veeder root s ump sensor 208.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Lab Certification	DOUBLE WALL SPILL BUCKET 3100.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill drop tube	OPW-710S	Manufacturer Approval	Equipment-Compatibility.pdf for E15 OPW dispenser sumps.pdf	
Ball Float Vent Valve	OPW 53VML	Lab Certification	BALL FLOAT.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Red Jacket P200UI-3RJ2	Manufacturer Approval	576047-305 red jacket mot or e15 proof.pdf	
Dispenser	Gilbarco Veeder Root NL1	Manufacturer Approval	01EncoreDispensers Booklet.pdf E15 compatible.pdf	
Nozzle	OPW-11BP-8400-E25-UL	Manufacturer Approval	Equipment-Compatibility.pdf for E15 OPW dispenser sumps.pdf	
Hose	CT-3409-E85	Manufacturer Approval	IFS-En-Petroleum-Dispensing-Hose-Brochure.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name SAMANTHA HUNTER ☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Job Title customer service coordinator
Company Neumayer Equipment Company, Inc.
Phone Number (314) 772-4501
Email testing@neumayerequipment.com
Contractor License # IL1502