



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 4043661

Facility Name Love's Travel Stop #367
Address 505 South Persimmon Drive
Le Roy, IL 61752
County McLean
Contact Name Aaron Negri
Phone Number (309) 962-3060

Tank - 7

Tank Material Composite Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 7/27/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	BioFuels Compatibility 2018.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet B99 & E85.pdf	
Flex Connector Steel	OPW / FCXX Series	Manufacturer Approval	below-ground-products-fue l-compatibility-matrix-2018.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW	Manufacturer Approval	Environ - Legacy FRP Sump s.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder-Root	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	577013-750-12_Interstitial_Sensor_for_Double-Wall_Fiberglass_Tanks B20 & E15.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	LineLeakDetection B99 & E 85.pdf	Replacing from Permit Application.
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval	V-R_794380-321_SumpSensor .pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	opw-fuel-compatibility-be low-ground-products-2018. pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder-Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	
Overfill Drop Tube Valve	Franklin Fueling Systems	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet B99.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Veeder-Root / Red Jacket	Manufacturer Approval	Red Jacket STP B99 & E85. pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Paul carrabbia
Job Title Project Manager
Company Illinois Oil Marketing Equipment, Inc.
Phone Number (309) 678-8061
Email pcarrabbia@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.