



Blended Fuel Compatibility Form

Facility - 6007982

Facility Name Travel Centers of America
Address 819 Edwardsville Road
 I-55 & I-70 & State Route
 162
 Troy, IL 62294
County Madison
Contact Name Jim Schenker
Phone Number (440) 808-7368

Tank - 15

Tank Material Tank - Fiberglass Brine Filled
 Double Wall Containment
 Solutions
Tank Capacity 20,000
Tank Product B-99
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	biofuel-compatibility.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flex Connector Steel	FLEX-ING	Lab Certification	12-flexing_biodiesel.pdf	New from Permit Application.
Fiberglass Double Wall	Ameron Fiberglass Dualoy 3000/LCX	Manufacturer Approval	10-NOV.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	BRAVO	Manufacturer Approval	15-Bravo_Sumps_AlternativeFuels_R3.pdf	New from Permit Application.
Single Wall UDC Sump	BRAVO	Manufacturer Approval	15-Bravo_Sumps_AlternativeFuels_R3.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	846397-110	Lab Certification	18-Veeder-Root Fuel Compatibility Letter - Execute d - 2015-09-23.pdf	
INTERSTITALE SENSOR	794380-304	Lab Certification	Single-Point Mini-Hydrostatic Sensor _ Veeder-Root .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FRANKLIN FUELING 403171901	Manufacturer Approval	Mechanical Leak Detectors _ Franklin Electric Fuel ing Systems.pdf	New from Permit Application.
Sump Sensor with positive shutdown	VEEDER ROOT 794380-351	Lab Certification	18-Veeder-Root Fuel Compatibility Letter - Execute d - 2015-09-23.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	1C-3122D	Lab Certification	opw-fuel-compatibility-matrix-below-ground-products-2018 (3).pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Lab Certification	71SO_Overfill_Prevention_Valve (2).pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	2HP AG FIXED SPEED SUBMERSIBLE TURBINE PUMP W/12" RISER FRANKLIN FUELING STPAG200-VL2-12	Lab Certification	FFS-0216 (UL) FFS Product Catalog.pdf	
Dispenser	ENCORE 300	Lab Certification	13-Encore UL Approval_Bio Diesel.pdf	
Nozzle	ENCORE 300	Lab Certification	13-Encore UL Approval_Bio Diesel.pdf	
Hose	ENCORE 300	Lab Certification	13-Encore UL Approval_Bio Diesel.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
SEAL/GASKET	Gasola	Lab Certification	11-GASOILA-TDS-hard-set.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
DOPES	GASOILA	Lab Certification	11-GASOILA-TDS-hard-set.pdf	

Correspondence Contact

<p>Submitter Name SAMANTHA HUNTER</p> <p>Job Title CUSTOMER SERVICE COORDINATOR</p> <p>Company NEUMAYER EQUIPMENT</p> <p>Phone Number (314) 772-4501</p> <p>Email testing@neumayerequipment.com</p> <p>Contractor License # IL1502</p>	<p><input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.</p>
--	--