

**Blended Fuel Compatibility Form**

Facility - 3012076

Facility Name Gold Star FS Fuel 24
Address 1601 1st Avenue
Silvis, IL 61282
County Rock Island
Contact Name Greg Rohman
Phone Number (309) 937-3369

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 12,000
Tank Product E-85
Tank Install Date 6/27/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		You will find the compatibility on page 4

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling / TM4236-0/0-OC-S	Manufacturer Approval		
Single Wall UDC Sump	Franklin Fueling / LMM-3617	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root / 794380-345	Manufacturer Approval		
ATG Probe	Veeder-Root 846391-410	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root / 859080-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder-Root / 794380-323	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall UDC Sump	Veeder-Root / 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge 1C-3112D	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW	Manufacturer Approval		
Overfill Alarm	Veeder-Root	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling / ISTR VSZ-VLZ	Manufacturer Approval		pg 5
Dispenser	Gilbarco / Encore NL1 & NL3 with E-85 upfit	Manufacturer Approval		
Dispenser Hose	Flexsteel Futura / Ethan-ALL Dispensing Hose	Manufacturer Approval		pg 3
Nozzle	OPW / 11BP-0992-E85	Manufacturer Approval		
Swivel	Husky / 6350	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Gilbarco / Encore NL1 & NL3 with E-85 upfit	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dopes	Gasola / EE16	Manufacturer Approval		

Correspondence Contact

Submitter Name Zak Paxton
Job Title Compliance Manager
Company Illinois Oil Marketing Equipment
Phone Number (309) 347-1819
Email compliance@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.