

**Blended Fuel Compatibility Form**

Facility - 2045665

Facility Name DL Food Mart, Inc.
Address 1600 W. Lake St.
Roselle, IL 60172
County Du Page
Contact Name Mukhtar Khan
Phone Number (630) 237-4769

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 8/14/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions bio fuel-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	OPW, E85-10P	Manufacturer Approval	opw shear valves.pdf	From Permit Application
Ball Valves	691BSS	Manufacturer Approval	Morrison E85 ss ball valve.pdf	From Permit Application
Flex Connector Steel	Hose Master, Fire Shield	Manufacturer Approval	hose master flex connectors.pdf	From Permit Application
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	NOV LCX pipe and fittings .pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	containment solutions tanks & all products.pdf	
Single Wall UDC Sump	OPW, Pisces series	Manufacturer Approval	opw all products.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root, 794380-345	Manufacturer Approval	veeder root sensors all.pdf	From Permit Application
ATG Probe	Veeder Root, 846397-409	Manufacturer Approval	veeder root probes.pdf	From Permit Application

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	Franklin MLD AG.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	veeder root sensors all.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	opw all products.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Gilbarco NL1	Manufacturer Approval	gilbarco dispener e85 certification letter.pdf	
Submersible Turbine Pump	Franklin Fueling, STPAG	Manufacturer Approval	franklin stp.pdf	From Permit Application
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Continental, Futura Etan-all	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ed Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.