



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 1045207

Facility Name Conserv FS, Inc.
Address 7222 Cunningham Rd.
Rockford, IL 61102
County Winnebago
Contact Name Mike Glendenning
Phone Number (815) 693-3323

Tank - 1

Tank Material Composite Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 10/16/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P200SC	Manufacturer Approval		
Shear Valve	OPW - 10RF-200	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW Pisces TSM-4842 Poly Sump	Manufacturer Approval		
Single Wall UDC Sump	OPW / DS-1242	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	INCON / ULS/UHS	Manufacturer Approval		
ATG Probe	INCON / LL@ Series	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Vaporless _ 99LD-2000 with LD2-SSVS vent kit	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	INCON / TSP- ULS	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW - 1-2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO-410CTB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin FE Petro - ISTAPG M200-VL2	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Patrick O'Brien
Job Title Sales Manager
Company Howard Lee and Sons, Inc.
Phone Number (815) 298-3767
Email patricko@hleeasons.com
Contractor License # IL456

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.