



### Blended Fuel Compatibility Form

<b>Facility - 2012192</b>		<b>Tank - 5</b>	
<b>Facility Name</b>	840 West Rollins, LLC	<b>Tank Material</b>	Fiberglass Double Wall
<b>Address</b>	840 W. Rollins Rd. Round Lake, IL 60073	<b>Tank Capacity</b>	8,000
<b>County</b>	Lake	<b>Tank Install Date</b>	8/17/2018
<b>Contact Name</b>	Ibrahim Sallah	<b>Current Product on File</b>	Gasoline - Premium
<b>Phone Number</b>	(347) 499-3935	<b>Newly Reported Product</b>	E85

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions bio fuel-compatibility.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	ameron fiberglass pipe.pdf	
Shear Valve	OPW 10	Manufacturer Approval	OPW compatibility.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	containment solutions tanks & all products.pdf	
Single Wall UDC Sump	BRAVO B1000	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root 794380-345	Manufacturer Approval	VR FRP interstitial sensor.pdf	
ATG Probe	Veeder-Root 846397	Manufacturer Approval	veeder root probes.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro Stp MLD AG	Manufacturer Approval	Franklin MLD AG.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder-Root 794380-323	Manufacturer Approval	VR E85 sump sensor.pdf	
Sump Sensor in Single Wall UDC Sump	veeder-root 794380-323	Manufacturer Approval	VR E85 sump sensor.pdf	

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112D	Manufacturer Approval	Opw spill containers.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	FRANKLIN FUELING 708	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
3+1 dispenser	Wayne Ovation2 EB23	Manufacturer Approval	Wayne Ovation EB23.pdf	
Submersible Turbine Pump	FE PETRO STPAG	Manufacturer Approval	E85 submersible info sheet.pdf	
Nozzle	OPW 11BP	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Goodyear	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill cap	OPW	Manufacturer Approval	OPW compatibility.pdf	

### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasoil E-Seal	Manufacturer Approval	gasoil dope.pdf	

### Correspondence Contact

**Submitter Name** Jim Veverka  
**Job Title** PROJECT MANAGER  
**Company** B&K Equipment  
**Phone Number** (708) 474-3344  
**Email** jim.veverka@bkequip.com  
**Contractor License #** IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.