

**Blended Fuel Compatibility Form**

Facility - 2046192

Facility Name Speedway #7412
Address 1110 Irving Park Road
Bensenville, IL 60106
County Du Page
Contact Name Andrew Wagner
Phone Number (630) 616-7611

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E85
Tank Install Date 7/21/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	other-equipment-compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall UDC	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/846391-407	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root/794380-345	Manufacturer Approval	577013-750-13_Solid-State Alternative Ethanol Fluid Interstitial Sensor_for_Double-Wall_Fiberglass_Tanks.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/859080-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root/794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW Edge Series -3100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	Replacing from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM Series	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	Replacing from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Flex Dispenser	Gilbarco Encore	Manufacturer Approval	Encore Flex Fuel Dispenser_Gilbarco Veeder-Root.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company America Petropump Services LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.