

**Blended Fuel Compatibility Form**

Facility - 2016461

Facility Name 2807 West 71st Chicago, LLC
Address 2807 W. 71st Street
Chicago, IL 60629
County Cook
Contact Name Syed Kirmani
Phone Number (718) 501-4364

Tank - 8

Tank Material Tank - Fiberglass Double Wall
Containment Solutions
Tank Capacity 6,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	NOV-Containment Solutions certification.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech XP 1500	Manufacturer Approval	FFS-0524 XP Flexible Pipe work Datasheet.pdf	New from Permit Application.
Shear Valve	OPW	Manufacturer Approval	opw-10-series-emergency-shut-off-valves-E85 compatible.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions NOV	Manufacturer Approval	NOV-Containment Solutions certification.pdf	New from Permit Application.
Single Wall UDC Sump	Bravo sump	Manufacturer Approval	Bravo+Fiberglass+Sumps.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder root	Manufacturer Approval	Veeder+Root+Mag+Probes+for+Alternative+Fluids.pdf	New from Permit Application.
ATG Probe	Veeder Root	Manufacturer Approval	Veeder+Root+Mag+Probes+for+Alternative+Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veederroot Presurised Mechanical Leak detector.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root	Manufacturer Approval	Veederroot sump sensor.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Opw	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground).pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Opw	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground).pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Fe Petro	Manufacturer Approval	FE+Petro+Products+with+Alt+Fuels.pdf	
Suction Pump	Fe Petro	Manufacturer Approval	FE+Petro+Products+with+Alt+Fuels.pdf	
Dispenser	Wayne	Manufacturer Approval	Dover Fueling Solutions Announces E40 to E85 Upgrades to Wayne Ovation Fuel Dispensers.pdf	
Nozzle	OPW	Manufacturer Approval	OPW 11a-and-11b-automatic - nozzles -e85.pdf	
Hose	Continental	Manufacturer Approval	Continental+E25++E85+Hose+Spec+and+Installation+Instructions.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Top Seal	OPW	Manufacturer Approval	opw-634-series-tight-fill - top-seal-caps-2018.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Adhesive	Gasolia	Manufacturer Approval	Gasolia GE04 Datasheet.pdf	

Correspondence Contact

Submitter Name Raju Penumatsa
Job Title Owner
Company Innovative Constructions Technology LLC
Phone Number (630) 747-3404
Email iconstructions81@gmail.com
Contractor License # IL002453

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.